

Company name: Conidia Bioscience Ltd

Registered User: David Armitage

Address:

Test date: 05-NOV-2018

Post code:

GPS location:

Country:

Fuelstat result number: 2,210

Customer reference: 001

Printout date: 05-NOV-2018

Identity: Update Test

Bacteria: **Heavy**

Asset:

Fungi: **Heavy**

Tank:

Hormoconis resinae: **Heavy**

Fuel lot:

Overall result: **Heavy**

Fuelstat test lot:

Test method: ASTM D8070-16

Comments

FUELSTAT® Result data interpretation and guidance

Alert level	Phase	Target antigen limits
Negligible	Fuel Water	Up to 150 µg/L Up to 33 µg/ml
Negligible — Maintain good housekeeping practices.		
Moderate	Fuel Water	Between 150-750 µg/L Between 33-166 µg/L
Moderate — Repeat the test to confirm the result and increase the frequency of water drainage.		
Heavy	Fuel Water	Greater than 750 µg/L Greater than 166 µg/ml
Heavy — Consider remedial treatment, such as increased water drainage and/or biocide treatment. Seek further advice if required.		

Phone make: Apple

Portal version: 1.2.2

Phone model: iPhone 6s

Analysis approved by:

App version:

Disclaimer — FUELSTAT® Result is designed for use with tests which are fully compliant with ASTM D8070-16. However, readings obtained using FUELSTAT® Result are currently outside the scope of ASTM D8070-16. Operators should visually validate test results as per ASTM D8070-16. The accuracy of this report may be dependent on the accuracy of the sample provided. Full terms of use available on the Conidia Bioscience Ltd. website www.conidia.com. For Any Technical Assistance Telephone: +44 (0)1491 829102

Conidia Bioscience Limited: 3 Acorn Business Centre, Northharbour Road, Cosham, Portsmouth, PO6 3TG, United Kingdom.
Registration number: 03965471 | VAT number: 760 2156 55 | www.conidia.com

